

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 216

Dated: 28/06/2023

It is certified that an inspection team headed by Shri Pasween Kumar Matwa

(Name of Officers with designation) from Ass. Engineer PHED CITY SUB. Dn. III rd

(Name of Department/ Office) inspected the Tagore International Sr. Sec. School Sikar  
Nawalgarh Road Sikar

(Name & Address of the school) on 22/06/2023 (date of inspection), checked the water test report

submitted by the school and found that the school has potable drinking water for students and staff of the

institution and is having provision for running water in the toilets and maintaining hygienic sanitation

condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal: Pasween  
सहायक अभियन्ता  
जनक स्वास्थ्य अभियंत्रण विभाग

Name : Pasween Kumar Matwa  
नगर उपलब्ध तृतीय, सीकड़

Designation : Ass. Engineer PHED CITY SUB. Dn. III rd

Assistant Engineer of  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : PHED SIKAR

Aswalg  
सचिव

श्री अशोक विद्यापीठ शिक्षा समिति

To

Tagore International School

Nawalgarh Road Sikar

(Name & Address of the Institution)

Principal (1220838)  
Tagore International Sr. Sec. School  
Nawalgarh Road, SIKAR (Raj.)  
DISE Code 03130510406

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

**OFFICE OF THE SENIOR CHEMIST  
PUBLIC HEALTH ENGINEERING DEPARTMENT, LABORATORY SIKAR  
REPORT OF THE CHEMICAL EXAMINATION OF WATER**

Not valid for legal case

No. Lab/Tech(Private Chem.Rep)/2023-2024/366

Date - 28/06/2023

To,

Secretary  
Tagore International Sen.Sec.School  
Kisan Colony,Nawalgarh Road , Sikar (Raj.)

District: Sikar  
Block Piprali

Reference :Your Letter No- 187 Date 22.6.2023

Sample Collected by- Sh.Ashok kumar

Date of Receipt : 26.06.2023

Source		Permissible value as per B.I.S. 10500/2012	Tap RO
Source Location			
Gram Panchayat			Sikar
Village/Town/ City		Desirable limit	Sikar
Habitation			Sikar
Date of Collection			22.6.2023
Date of Examination			28.06.2023
Lab. Sample No.			358

**Note :- All results Except pH are in mg/L**

	6.5 to 8.5	No Relaxation	6.69
pH			Clear
Turbidity (NTU)	1	5	Colourless
Colour (Hazen Units)	5	15	Smellless
Odour	Agreeable	Agreeable	20
Total Alkalinity (as CaCO <sub>3</sub> )	200	600	20
Total Hardness (as CaCO <sub>3</sub> )	200	600	10
Chloride (as Cl <sup>-</sup> )	250	1000	43
Nitrates (as NO <sub>3</sub> <sup>-</sup> )	45	45	3
Sulphate (as SO <sub>4</sub> <sup>-2</sup> )	200	400	0.04
Fluoride (as F <sup>-</sup> )	1.0	1.5	86
Total Dissolved Solids	500	2000	

**Remarks:- Sample not collected by Lab**

*[Signature]*  
Senior Chemist  
PHED Lab Sikar

No. Lab/Tech(Private Chem.Rep)/2023-2024/

Dated:

Copy to:

1 The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

*[Signature]*  
Senior Chemist  
PHED Lab Sikar